



**Northeast
Utilities**

107 Selden Street, Berlin, CT 06037

Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270
(860) 665-5000
www.nu.com

May 20, 2011

Ms. Linda Roberts
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RECEIVED
MAY 20 2011

ORIGINAL

**CONNECTICUT
SITING COUNCIL**

Re: Docket No. F-11 - Connecticut Siting Council Review of 2011 Forecasts of Electric Loads and Resources

Dear Ms. Roberts:

This letter provides the response to requests for the information listed below.

Response to CSC-01 Interrogatories dated 05/02/2011
CSC-001, 002, 003, 004, 005, 006

Very truly yours,

Christopher R. Bernard
Manager
Regulatory Policy - Transmission
NUSCO
As Agent for CL&P

cc: Service List

Witness: Robin E. Lewis
Request from: Connecticut Siting Council

Question:

CL&P's 2010 Forecast Report projected an annual electric energy usage increase of 0.2 percent and an annual peak load increase of 1.4 percent. CL&P's 2011 Forecast Report (CL&P Forecast) reports 0.9 percent and 2.0 percent as the updated numbers, respectively. Explain the increase.

Response:

There are 4 major drivers behind the increase in usage between the 2010 and 2011 forecasts. First, the price of electricity for all classes is lower in the 2011 forecast versus the price used in the 2010 forecast. A lower price of electricity leads to higher use per customer and higher forecasted sales. Second, the economic drivers for the residential and industrial classes are more optimistic for the 2011 forecast than the drivers used in the 2010 forecast. Third, forecasts for Distributed Generation (DG) usage, which would lead to a reduction to sales, is forecasted to be lower in the 2011 forecast, resulting in higher forecasted sales in 2011. Finally, forecasts for savings associated with Conservation and Load Management (C&LM) activities, which lead to a reduction to sales, are also forecasted to be lower in the 2011 forecast. All of the reasons listed above result in higher sales and peaks.

The Connecticut Light and Power Company
Docket No. F-11

Data Request CSC-01
Dated: 05/02/2011
Q-CSC-002
Page 1 of 1

Witness: Robin E. Lewis, David J. Bebrin
Request from: Connecticut Siting Council

Question:

On page 11 of the CL&P Forecast, there are no gigawatt-hours (GWh) reported from ISO-NE's Load Response Program (ISOLRP). Is this because the limited number of hours that the ISOLRP is in use results in a negligible energy savings in GWh? Explain.

Response:

Yes. In the forecast, CL&P assumed that customers who are in the ISOLRP will only be called to curtail load a few times each year so the impact on energy output is minimal.

Witness: Robin E. Lewis
Request from: Connecticut Siting Council

Question:

On page 11 of the CL&P Forecast, the Net Electrical Energy Output Requirements are listed. Are these based on the 50/50 forecast scenario? If yes, provide a similar table based on the Extreme Hot Weather Scenario.

Response:

Yes, the Net Electrical Energy Output Requirements ("Energy") are based on the 50/50 forecast. The Extreme Hot Weather Scenario is based on the single hottest peak day that has occurred during the more than 50 years that CL&P has been collecting weather data. CL&P does not currently have an Extreme Hot Weather Scenario for Energy. To construct one, a definition of extreme hot weather, as it pertains to Energy, would have to be determined. There are at least three ways that this could be defined:

- 1) Choose the hottest day from historical data for each individual day in the summer.
- 2) Choose the hottest month from historical data for each individual month in the summer.
- 3) Choose the hottest summer season from historical data.

There would be several variations on the above, depending on how the winter and shoulder months are treated and what dates to consider as part of the cooling season. While Option 1 would produce the highest energy forecast, it has an extremely low probability of occurrence, and would be the most difficult to compute. Thus, Option 1 has not been computed. Option 2 would be more likely to occur and would produce a lower energy forecast. Option 3 would be the most likely to occur and would produce the lowest energy forecast. Page 2 of 2 shows the results for options 2 and 3.

Adjustments to Output based on Extreme Hot Weather Scenarios

Option 3 - Extreme Hot Weather Scenario By Season

<u>Year</u>	<u>Unadjusted</u> <u>Output</u> GWH	<u>Distributed</u> <u>Generation</u> GWH	<u>Company</u> <u>Sponsored</u> <u>C&LM</u> GWH	<u>ISO-NE</u> <u>Load</u> <u>Response</u> GWH	<u>Adjusted</u> <u>Output</u> GWH	<u>Annual</u> <u>Change</u> (%)
HISTORY NORMALIZED FOR WEATHER						
2010					23,484	
FORECAST						
2011	24,519	(450)	(88)	-	23,981	2.1%
2012	25,134	(452)	(321)	-	24,361	1.6%
2013	25,706	(451)	(484)	-	24,771	1.7%
2014	26,252	(451)	(632)	-	25,168	1.6%
2015	26,684	(451)	(776)	-	25,457	1.1%
2016	27,147	(451)	(918)	-	25,777	1.3%
2017	27,438	(451)	(1,058)	-	25,930	0.6%
2018	27,775	(451)	(1,192)	-	26,133	0.8%
2019	28,091	(451)	(1,325)	-	26,316	0.7%
2020	28,426	(451)	(1,457)	-	26,518	0.8%
Compound Rates of Growth (2010-2020)						
	1.9%				1.2%	

Option 2 - Extreme Hot Weather Scenario By Month

<u>Year</u>	<u>Unadjusted</u> <u>Output</u> GWH	<u>Distributed</u> <u>Generation</u> GWH	<u>Company</u> <u>Sponsored</u> <u>C&LM</u> GWH	<u>ISO-NE</u> <u>Load</u> <u>Response</u> GWH	<u>Adjusted</u> <u>Output</u> GWH	<u>Annual</u> <u>Change</u> (%)
HISTORY NORMALIZED FOR WEATHER						
2010					23,484	
FORECAST						
2011	25,407	(450)	(88)	-	24,869	5.9%
2012	26,069	(452)	(321)	-	25,295	1.7%
2013	26,692	(451)	(484)	-	25,757	1.8%
2014	27,287	(451)	(632)	-	26,203	1.7%
2015	27,761	(451)	(776)	-	26,535	1.3%
2016	28,268	(451)	(918)	-	26,899	1.4%
2017	28,605	(451)	(1,058)	-	27,096	0.7%
2018	28,986	(451)	(1,192)	-	27,343	0.9%
2019	29,346	(451)	(1,325)	-	27,571	0.8%
2020	29,725	(451)	(1,457)	-	27,817	0.9%
Compound Rates of Growth (2010-2020)						
	2.4%				1.7%	

1. Sales plus losses and company use.

Witness: Robin E. Lewis, David A. Ferrante
Request from: Connecticut Siting Council

Question:

Provide the basic underlying assumptions associated with the distributed generation (DG) included in Table 2-2 of the CL&P Forecast, including but not limited to the DG projects approved, number of megawatts of each DG project, the number of units expected to go into service or the assumed probability that it will go into service, etc.

Response:

Distributed Generation ("DG") projects are developed in accordance with Public Act 05-01, *An Act Concerning Energy Independence* ("PA 05-01"). The forecast in Table 2-2 is comprised of 1) DG projects forecast at 100% of their MW capacity, and 2) DG projects forecast at less than 100% of their MW capacity, because their estimated in-service dates were further into the forecast period. There are 49 projects in the first group with an aggregate of 80.124 MWs, which are shown on page 2 of 3. There are 14 projects in the second group in varying degrees of development that account for an additional 8.530 MWs of DG capacity and are shown on page 3 of 3.

The Kimberly Clark DG unit has a capacity higher than the current peak demand of the Kimberly Clark facility. The peak load forecast presented in CL&P's FLR represents the peak load demand of its own customers. Thus, the DG forecast presented in Table 2-2 of the CL&P Forecast excludes the additional load that Kimberly Clark supplies to the grid over and above its own demand.

The DG that is presented in Table 2-2 reflects the projected load reduction at the time of the system peak, and thus, is lower than the sum of the non coincident probability weighted capacity of the projects shown on pages 2 and 3.

Projects forecast at 100% in-service	
Project Name	MW
Avon Convalescent Home, Inc	0.074
Biopur Inc.	0.225
Bradley Home- Cogen	0.074
Branford High School	0.240
Cabela's Retail Inc.	0.800
Cellu-Tissue	2.920
City of Danbury - High School	0.072
City Of Middletown - New High School	0.200
Component Technologies, Inc	0.295
Connecticut Natural Gas	0.072
Ct Center For Science & Exploration	0.200
Duncaster Inc (1)	0.148
Duncaster Inc (2)	0.148
Duncaster Inc (3) Aquatic Center	0.074
East Hartford Public Schools	0.240
Elim Park Baptist Home Inc.	0.074
Executive Square (Winn Properties)	0.074
Flanagan Industries (1)	0.640
Flanagan Industries (2)	0.157
Frito Lay Inc	3.772
Greater Hartford Jewish Community Center	0.150
Greenwich Hospital	0.280
Hartford Steam Company	3.510
Hebrew Home & Hospital	0.150
Hughes Health and Rehabilitation	0.075
International Skating Center Of Conn LLC	0.134
Jerome Home	0.074
Kimberly Clark	33.485
King's Daughters & Sons Hsg (Kingsway Apts)	0.075
Mashantucket MPTN Foxwoods	15.000
Mashantucket Pequot Tribal Center	0.074
Northwestern Connecticut YMCA	0.049
Norwalk High School (City Of Norwalk)	0.250
Pepperidge Farm	1.198
Plainville Electric Products Co. (Pepco)	0.375
Pratt & Whitney (UTC) Middletown	7.520
Pratt & Whitney (UTC) East Hartford	2.100
Saint Mary Home	0.075
Sheffield Laboratories (1)	0.250
Sheffield Laboratories (2)	0.325
Smithfield Gardens (Sha Corp)	0.074
Southington Care Center	0.074
Southington-Cheshire Community YMCA	0.074
UTC Fuel Cells	0.400
Wesleyan University	2.366
West Hartford Health & Rehabilitation (Brookview Corp)	0.074
Westover School	0.068
Whole Foods Market	0.200
Windham Public Schools (High School)	0.148
Total MW's	<u>79.124</u>

Projects forecast at <100%			
Project Number	Estimated in-service	Probability	Estimated MW
1	Jun-10	99%	0.396
2	Sep-10	90%	0.090
3	Sep-10	90%	0.068
4	Nov-10	80%	0.978
5	Mar-09	80%	0.936
6	Sep-10	75%	0.600
7	Nov-10	50%	2.059
8	Nov-10	50%	2.595
9	Sep-10	50%	0.038
10	Nov-10	50%	0.038
11	Nov-10	50%	0.030
12	Nov-10	25%	0.475
13	Jul-08	25%	0.098
14	Dec-11	6%	0.132
Total Estimated MW's			<u>8.530</u>

Witness: David J. Bebrin
Request from: Connecticut Siting Council

Question:

In the context of the Conservation and Load Management Program (C&LM Program), explain the difference between passive and active resources.

Response:

Active resources are dispatchable resources (demand response and some distributed generation) that must respond during shortage events. For example, resources entered into the ISO Demand Response Program are active resources because they are called to perform only for specific shortage events.

Passive resources are non-dispatchable resources (energy efficiency, plus a small amount of distributed generation) that reduce load during pre-defined hours and periods. Most C&LM measures are passive because they reduce load across a pre-defined operating period. For example, energy efficient lighting will reduce load whenever lights are on throughout the year.

The Connecticut Light and Power Company
Docket No. F-11

Data Request CSC-01
Dated: 05/02/2011
Q-CSC-006
Page 1 of 1

Witness: David J. Bebrin
Request from: Connecticut Siting Council

Question:
Is CL&P's C&LM Program limited to passive resources?

Response:
No. CL&P's C&LM programs have both "passive" and "active" resources. C&LM's Energy Efficiency resources are defined as passive. CL&P's C&LM Demand Response Resources (Real Time Emergency Generation and Real Time Demand Response) are defined as active.